


DAVID Y. IGE
GOVERNOR

JOSH GREEN
LT. GOVERNOR



Curt T. Otaguro
Comptroller

AUDREY HIDANO
Deputy Comptroller

STATE OF HAWAII
DEPARTMENT OF ACCOUNTING AND GENERAL SERVICES
STATE BUILDING CODE COUNCIL

P.O. BOX 119, HONOLULU, HAWAII 96810-0119

Subcommittee of Building Officials Meeting
Tuesday, April 21, 2020

To Join from PC, Mac, Linux, iOS or Android: <https://department-of-health-hawaii.zoom.us/j/609772591>

Or join by phone:

*Standard Long Distance charge could apply. Check with your provider and plan.

+1 669 900 6833 (US Toll) or +1 346 248 7799 (US Toll)

Meeting ID: 609 772 591

International numbers available: <https://department-of-health-hawaii.zoom.us/j/609772591>

MINUTES

Present:

Willard Nishigata	City & County of Honolulu
Douglas Haigh	County of Kauai
Neal Tanaka	County of Hawaii
Glen Ueno	County of Maui
Kika Bukoski	Plumbers and Fitters UA Local 675
Gregg Serikaku	PAMCA
Dwight Perkins (via phone)	IAPMO
Mark Kennedy	BIA
Clayton Oku	City & County of Honolulu

1. Call to order: 8:02 a.m.
2. The minutes were approved for January 21, 2020 meeting.
3. State Building Officials reviewed, approved, and forwarding to the State Building Code Council the Proposed Amendments to the 2018 UPC (V 1.5) with the following changes:

- Delete amendment to Appendix C 601.0 Single-Stack Vent System. C 601.1 Where Permitted.
- Revise the first sentence to amendment APPENDIX – HAWAII SBCC1 Item 906.1.1 Sidewall Venting to read as follows:

“ Where sidewall venting is utilized, the vent shall not terminate under a vented overhang of a building and shall be located in accordance with Section 906.2.”

4. Next meeting: TBD.
5. Meeting adjourned: 8:45 a.m.